Equipment	Service Report
	Yamaha Generator
Model -	YG 6600 DE Serial # 203879
PW # 201	Oil - 10W-30 1.16 qts.
Date	Service Performed
	Purchased from Norris Sales
	Changed engine oil and cleaned air filter element
	Installed new battery (NAPA 8223) and ran for 20 mins.
	West Generator checked out generator - everything O.K.
	Installed new foam air filter (Norris Sales - Yamaha 7CT-E4451-00)
	Changed engine oil and cleaned air filter element
9/23/2013	West Generator picked up for service-not running right-shuts off - new spark plug (NGK-BPR4)
	Installed new magneto (7RH-85640-00) and spark plug wire end (85G-82370-20)
	Installed new battery (Federal - 8U1L CCA-230) from Warehouse Battery Outlet
	Changed engine oil and cleaned and oiled air filter element
	West Generator checked out generator - Inspected, tested and performed operation check
	Ran for 30 minutes
	West Generator checked out generator - Inspected, tested and performed operation check
	Ran for 1 hour
	Ran for 1 hour
	Ran for 1 hour
8/11/2016	Installed new battery (Federal - 8U1L CCA-230) from Warehouse Battery Outlet and ran for
	30 minutes
8/30/2016	Took out and hooked up to traffic light at Welsh & Forty Foot Roads at 9:00AM to 11:00AM for
	PP&L so they could shut power down to run new lines for new Citidel Bank
	Took out to traffic light and ran for 1.5 hours due to power outage
	Ran for Holiday Lights Festival in Fischer's Park
	Ran for 1 hour
	Took out and hooked up to traffic light at Allentown Road & Woodlawn Drive at 9:30PM to 6:00AM
	due to a power outage
	Ran for Holiday Lights Festival in Fischer's Park
	Took out and hooked up to traffic light at Wambold & Detwiler Roads due to a power outage
	Took out and hot wired in traffic light at Forty Foot Rd. & Detwiler/Quarry Rds. for 1 hr. due to a
	power outage
	Took out and hooked up to traffic light at Wambold & Detwiler Roads due to a power outage
6/15/2018	Ran for 1 hr.

Sheet1

Sheet1