
125 - 180 KW

SOMMERS

DMT JD Series Generator Sets



Specifications

Model:

DMT125JD - DMT180JD

Engine:

John Deere

6076T/6076A Diesel 211-300 HP @ 1800 RPM (175-250 HP @ 1500 RPM)

Generator:

12 Lead Brushless

| Rated Output*: | 60 Hertz | 50 Hertz |
|--|----------------------|----------------------|
| Continuous Standby KW @ 0.8PF (KVA) | 125-180 (156-225) | 110-150 (137-187) |
| Prime Power KW @ 0.8PF (KVA) | 110-150 (137-187) | 100-130 (125-162) |
| Governed RPM | 1800 | 1500 |

*Other intermediate ratings are available.

| Operating Cycles | 4 |
|---|----------------------------|
| Number of Cylinders | 6 |
| Bore and Stroke4.56 Piston Displacement4.56 | 6 x 4.75 in (116 x 121 mm) |

Standby Rating is applicable for supplying electrical power in the event of normal utility power failure. No overload capability is available for this rating. This rating may be used for continuous service for as long as the emergency may last. This rating conforms with the BS 649:1958 overload rating and DIN "B" 6270.

Prime Power Rating is applicable for supplying electric power in lieu of commercially purchased power. Intermittent overloads up to the Standby Rating are allowable. This rating may be used for continuous service in commercial applications and it conforms with BS 649:1958 and DIN "a" 6270 for generator set applications.

Standard Equipment:

Air Cleaner:

Dry Type, Heavy Duty

Electrical:

12 VDC Alternator 12 VDC Starter

Exhaust Manifold:

Dry

Filters:

Lubricating Oil and Fuel

Generator:

Brushless Revolving Field, 4 Pole with Solid State Voltage

Regulator

Instruments:

Unit Mounted with AC Meters, Engine Instruments, Shutdown Indicators and Automatic Start/Stop

Radiator:

High Ambient with Blower Fan

and Guard


Safety Controls:

Low Oil Pressure, High Coolant

Temperature, Engine Overspeed and Overcrank

Subbase:

Full Length, All Welded Structural Steel Construction



Specific Rated Output

Continuous Standby KW (KVA) @ 0.8PF

| Model | Engine | 60Hz | 50Hz |
|----------------------------------|-------------------------|-------------------------------------|-------------------------------------|
| DMT125JD DMT150JD DMT180JD | 6076T 6076A 6076A | 125 (156) 150 (187) 180 (225) | 110 (137) 130 (162) 150 (187) |
| Prime Power | KW (KVA) @ | 0.8PF | |
| DMT125JD DMT150JD DMT180JD | 6076T 6076A 6076A | 110 (137) 134 (167) 150 (187) | 100 (125) 117 (146) 130 (162) |
| Approx. Fuel | Consumption | @ Full Load U | .S. Gal/Hr |
| DMT125JD DMT150JD | | 10.6 11.7 | 8.7 9.9 |

| DMT125JD | 10.6 | 8.7 |
|----------|------|------|
| DMT150JD | 11.7 | 9.9 |
| DMT180JD | 13.4 | 12.0 |
| | | |

Approximate Dry Weight

| DMT125JD | 3400 lbs. (1542 kg) |
|----------|---------------------|
| DMT150JD | 3700 lbs. (1678 kg) |
| DMT180JD | 3900 lbs. (1769 kg) |



SOMMERS MOTOR GENERATOR SALES LTD. 35 Elizabeth St., Tavistock, Ont NOB 2RO Telephone 519-655-2396 FAX 519-655-3176

Generator Design Features

Construction: Conforms with National Electrical Manufacturers Association NEMA MG1-22; British Standard BS 2613-1970; Canadian Standards Association listed.

Bearings: Single row ball, shielded.

Cooling: Cast aluminum alloy ventilating fan, part of drive assembly.

Drive Coupling: Positive alignment, flexible laminated steel disk with 400% safety factor.

Exciter: Brushless rotating half wave rectification exciter solid state components inboard of rotor bearing.

Main Frame: Steel construction with rear mounted connection box.

Rotor: One piece 4 pole laminations, amortisseur windings and coil supports, layer wound, rotor shrunk fit and keyed to shaft, dynamically balanced to withstand 25% overspeed. Epoxy coated for abrasion and humidity protection.

Stator: 10/12 lead or 4 bus bar, suitable for 3 or 4 wire Y connection. Epoxy coated for abrasion and humidity protection. (Optional vacuum pressure impregnation)

Temperature Rise: Rotor and stator Class F insulation meet NEMA Class F standards.

Voltage Regulator: Solid state with SCR control. Modular construction, RFI filter for suppression of conducted electromagnetic interference to levels meeting most commercial requirements and with under frequency protection. Protected against high humidity conditions by hermetically sealed power control diodes. Voltage regulation is within j1% no load to full load

* Voltages Available:

| bitages Av | 3 Wire Y | 4 Wire Y |
|------------|--|------------|
| | 208 to 240 | 120/208 to |
| 60 Hz | CALL HEROTO | 139/240 |
| | 380 to 480 | 220/380 to |
| erelate la | PART OF STREET BY | 277/480 |
| 1217-192 | 190 to 208 | 110/190 to |
| 50 Hz | The state of the s | 120/208 |
| | 380 to 416 | 220/380 to |
| | A Leading of the Land | 240/416 |

^{*} For other voltages, consult factory.

CARBON Building GEN

FUEL OIL DISTRIBUTOR INSPECTIONS APPLIANCES - COMPREHENSIVE

REPORT NUMBER: A-08354

OWNER/OPERATOR: ONTALED CLEAN WATER ABENCY

BLUE WATEL HWY, GRAND BEND TELEPHONE NO. 519-238-8466 LOCATION: 71155 OWNER'S ADDRESS (If different from above):

| | 1 ^{sl} . | APPLIANCE | = | 2 nd . A | PPLIANCE | |
|--|-------------------|-----------|-------|---------------------|----------|-------|
| Type of Appliance | GENERA | TOR | | | | |
| Manufacturer | STAM | | 7 | | | - |
| Model | | | | | | |
| Date of Manufacture or Age in Years | 125- | | 2 | | | |
| Size (BTU/Hr) | 199 | 13 | | | | |
| | 125 | KW | | | | |
| Serial No. | 0930 | 5255 | 17 | | | |
| Is the appliance approved? | ₩ Yes | □ No | | ☐ Yes | □ No | |
| 2. Is the appliance installed in accordance with the fuel oil code? | Yes | □ No | | ☐ Yes | □ No | |
| Is the appliance being used in accordance with its approval? | V Yes | □ No | | ☐ Yes | □ No | |
| Is the appliance venting installed in accordance with the fuel oil code? | Yes | □ No | | ☐ Yes | □ No | |
| 5. Is the venting system free of defects, debris or corrosion | ☑ Yes | ☐ No | | ☐ Yes | □ No | |
| Is the vent sized properly? | ☑ Yes | □ No | | ☐ Yes | □ No | |
| 7. Is proper combustion and ventilation air openings installed? | Yes | ☐ No | □ N/A | ☐ Yes | □ No | □ N/A |
| 8. Is the installation free of indications of heat exchanger cracks, defects in the refractory, pot and/or heat shields? | Yes | □ No | | ☐ Yes | □ No | |
| Are all limits and safety controls properly installed? | Yes | □ No | | ☐ Yes | □ No | |
| 10. Is the appliance installed with appropriate clearances from combustibles? | Yes | □ No | ٠ | ☐ Yes | □ No | |
| 11. Are the results of combustion analysis acceptable? | Yes | □ No | | ☐ Yes | □ No | |
| 12. If required, is there a proper chimney cleanout? | ☐ Yes | □ No | ₩ N/A | ☐ Yes | □ No | □ N/A |
| 13. Is the chimney properly lined? | Yes | □ No | ☑ N/A | ☐ Yes | □ No | □ N/A |
| 14. Is the vent liner fitted with proper flashing, cap and base T? | ☐ Yes | □ No | ₩ N/A | ☐ Yes | □ No | □ N/A |
| 15. If there is a sidewall vent attached to the appliance is it installed according to code and the manufacturer's instructions? | ☐ Yes | □ No | M N/A | ☐ Yes | □ No | □ N/A |
| NOTES: (any "No" answers must be explained in this section and the affected equipment repaired, replaced or tagged). | | | | | | |
| COMMENTS: | | | | | | |
| | - YE-14 | - | | | | _ |
| | | | | | | |

Technician's Name (please print clearly): DENNIS SCHMEAT Telephone: 5/9-3/9-96/2 Certificate No.: 0707776 0874 Date: JAN-19-Technician's Signature: