# Rochester Fire Department

# Pump Service Test Record

Date: <u>5-8-20/9</u>	Apparatus #: $RT2$	City ID #: <u>0346/3</u>	-
Date.	Apparatus #.	City ID ir. <u>0 2 101 2</u>	-

Manufacturer: <u>HALE E-ONE</u> Pump Manufacturer: <u>Hale</u>

### **I Positive Pressure Test**

1.) Excessive water leaking from bottom of pump? No Yes

#### **II Vacuum Test**

Minutes	In. Hg
0	23
2	5
5	0.6

### **III Priming Device Test**

1.) Time until water flows from draft: 30 seconds.

# **IV Pumping Tests**

150psi - 100% Capacity Test

Minutes	Water Temp	Oil PSI	Hand Held RPM Counter	RPM	Dash Tachometer	Pump PSI	Pitot Reading
0	133	56	1624	1612	1500 RM	165	100
5	132	56	1624	1612	1500 RPM	165	100
10	184	52	155-5	1614	1500 1CPM	160	100
15	207	45	149	1614	1500 RPM	160	100
20	214	46	150.5	1614	1500 RPM	160	100

# 10% Overload Test (165psi/100% Capacity)

Minutes	Water Temp	Oil PSI	Hand Held RPM Counter	RPM	Dash Tachometer	Pump PSI	Pitot Reading
0	216	48	157.2	1662	1500 RRM	165	105
5	250	41	157.5	1664	1700 APM	טרו	105

### Pressure Controller Tests.

Test	Start	End	Rise
150psi	150	160	10
90psi	90	106	10

# IV Pumping Test (Con't)

"Spurt" Test

Hand Held RPM Counter	RPM	Dash Tachometer	Pitot ∧Reading	Tip Size	GPM
THE STATE OF THE S	/	V/ H	-		
		1-7			

200psi - 70% Intermediate Test

Minutes	Water Temp	Oil PSI	Hand Held RPM Counter	RPM	Dash Tachometer	Pump PSI	Pitot Reading
0	213	46	160-6	1690	1700	700	78
5	217	48	156.6	1685	1700	200	78
10	2/9	46	153.4	1685	1700	200	78

250psi - 50% Capacity Test

Minutes	Water Temp	Oil PSI	Hand Held RPM Counter	RPM	Dash Tachometer	Pump PSI	Pitot Reading
0	220	47	176.7	1865	1960	250	40
5	227	42	175.6	1865	1900	250	40
10	231	448	179-4	1864	1900	210	40

Pressure Controller Test

Test	Start	End	Rise
250psi	250	250	O

V Other (If answering yes, document exact issues below)

☐ No	Yes
□ No	☐ Yes ✓
☐ No	Yes
☐ No	Yes
gave 1	not working
Monte	
N	
	□ No □ No □ No